

Durand Septic Service  
P.O. Box 495  
Dallas City, IL. 62330  
(217) 852-3115

To: Dick Pardall  
1972 Franklin Road  
West Point, Iowa 52656

Date: 6-19-24

Inspection:

Durand Septic Service the week of 5-9-24, performed a septic inspection at the following property at 250 section line road Dallas City, Illinois. (Pontoosuc / Rio Vista addition.)

Durand Septic Service dyed and loaded the septic system, the septic system performed well. We located the septic tank, which is a 1000 gallon concrete septic tank. We pumped the septic tank and inspected the baffles and the baffles were in good working order.

No sign of any dye was found on the property or surface discharging. We believe this is a working, legal septic system at this time. Therefore this septic system **PASSED** the septic inspection.

This is how it performed the day of septic inspection. This is not to be construed as a warranty or guarantee going forward.

Thank You!

Durand Septic Service  
Keith A. Durand  
049-020134  
Colton K. Durand  
049-034127